


VŠB TECHNICKÁ UNIVERZITA OSTRAVA | VSB TECHNICAL UNIVERSITY OF OSTRAVA



[www.vsb.cz](http://www.vsb.cz)

0

---



---



---



---



---



---



---

VŠB TECHNICKÁ UNIVERZITA OSTRAVA | FAKULTA STROJNÍ | KATEDRA AUTOMATIZAČNÍ TECHNIKY A ŘÍZENÍ

## Lecture No. 7 LPaS 2023

doc. Ing. Jaromír ŠKUTA, Ph.D.  
Tel: 596 994 119  
E-mail: jaromir.skuta@vsb.cz

1

---



---



---



---



---



---



---

VŠB TECHNICKÁ UNIVERZITA OSTRAVA | FAKULTA STROJNÍ | KATEDRA AUTOMATIZAČNÍ TECHNIKY A ŘÍZENÍ

### What do you find out?

- PLC input/output addressing
- I/O configuration and assignment
- Time division of the task – Task
- Priorities
- Communication interface
- ILAN
- ... .

2

---



---



---



---



---



---



---

VŠB TECHNICKÁ FAKULTA KATEDRA  
UNIVERSITA STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA TECHNIKY A ŘÍZENÍ

## Addressing, Configuration, Diagnostics

Advant Controller 500

The diagram shows the Advant Controller 500 with its I/O assignments. It has 16 DI inputs (labeled 1.0 to 1.16) and 16 DO outputs (labeled 1.0 to 1.16). It also has 16 AI inputs (labeled 2.0 to 2.16) and 16 AO outputs (labeled 2.0 to 2.16). There are also 16 DI inputs (labeled 3.0 to 3.16) and 16 DO outputs (labeled 3.0 to 3.16). The controller is connected to a power source (16 DI 16 DC) and an output (Output 24 V DC 0.5 A). Below the controller, there is a photograph of two people working at a computer.

3

VŠB TECHNICKÁ FAKULTA KATEDRA  
UNIVERSITA STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA TECHNIKY A ŘÍZENÍ

## Addressing variables BOOL, BYTE, WORD, DWORD

Address	Addr	Addr + 1	Addr + 2	Addr + 3
BYTE	16#xxxx x000	16#xxxx x001	16#xxxx x002	16#xxxx x003
BOOL	%IB0	%IB1	%IB2	%IB3
	7 ... 0	7 ... 0	7 ... 0	7 ... 0
	%IX0.7 ... %IX0.0	%IX1.7 ... %IX1.0	%IX2.7 ... %IX2.0	%IX3.7 ... %IX3.0
WORD		%IW0		%IW1
	15 ... 8	7 ... 0	15 ... 8	7 ... 0
DWORD			%ID0	
	31 ... 24	23 ... 16	15 ... 8	7 ... 0

Examples:

%IX0.0 := TRUE	
%IB0 := 1	:= 16#01
%IW0 := 256	:= 16#100
%ID0 := 16777216	:= 16#01000000
(Bit 8 = TRUE)	
%IX3.0 := TRUE	
%IB3 := 1	:= 16#01
%IW1 := 1	:= 16#0001
%ID0 := 1	:= 16#00000001

4

VŠB TECHNICKÁ FAKULTA KATEDRA  
UNIVERSITA STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA TECHNIKY A ŘÍZENÍ

## Example: Addresses of headquarters and com. module 1

The diagram shows a PLC module with several pins labeled C, P, U, and FBP. Red lines point from these labels to specific pins on the module. To the right of the module is a table of addresses for the I/O bus and COM modules.

	I/O bus	COM1	COM2	FBP
C	0000..0999	%IB0 ... %IB4095	1000..1999	%IW0 ... %W2047
P		2000..2999	3000..4095	%ID0 ... %ID1023
U		%AO0 ... %AO4095		%IX0.0 ... %IX4095.7
FBP				

	I/O bus	COM1	COM2	FBP
C	0000..0999	%IB0 ... %IB4095	1000..1999	%IW0 ... %W2047
P		2000..2999	3000..4095	%ID0 ... %ID1023
U		%AO0 ... %AO4095		%IX0.0 ... %IX4095.7
FBP				

Coupler 1	Inputs (4kB)	Linie 1	
			%IB1.0 ... %IB1.4095
			%IW1.0 ... %IW1.2047
			%ID1.0 ... %ID1.1023
			%IX1.0 ... %IX1.4095.7
	1.0000 ... 1.4095		
			%QB1.0 ... %QB1.4095
			%QW1.0 ... %QW1.2047
			%QD1.0 ... %QD1.1023
			%QX1.0.0 ... %QX1.4095.7

5

VŠB TECHNICKÁ FAKULTA KATEDRA  
UNIVERSITA STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA STROJNÍ TECHNIKY A ŘÍZENÍ

**Addressing: arrangement by Byte**

% IBO	→ %IW0	%IX0.0 až %IX0.7	→ % ID0
% IB1	→ %IW0	%IX1.0 až %IX1.7	
% IB2	→ %IW1	%IX2.0 až %IX2.7	
% IB3	→ %IW1	%IX3.0 až %IX3.7	
<b>% IB4095</b>		→ %IW2047	%IX4095.0 až %IX4095.7

6

---

---

---

---

---

---

VŠB TECHNICKÁ FAKULTA KATEDRA  
UNIVERSITA STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA STROJNÍ TECHNIKY A ŘÍZENÍ

**Settings for the target system: selection of central processing unit (CPU)**

Target Settings  
Configurator: None OK Cancel

Target Settings  
Configurator: A520/PIN8 OK Cancel

Detail informations about system technology:

7

---

---

---

---

---

---

VŠB TECHNICKÁ FAKULTA KATEDRA KATEDRA  
UNIVERSITA STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA STROJNÍ TECHNIKY A ŘÍZENÍ

**Control configuration: CPU parameters**

AC500  
CPU parameters[FOG]  
IOBus[FO]  
Interfaces[FO]  
COM1 - Online acce  
COM2 - Online acce  
FBP - none[SLOT]  
Coupplers[FO]  
internal - none[SLOT]

Module parameters

Index	Name	Value	Default	Min	Max
1	Auto run	On	On		
2	Error LED	On	On		
3	Check Board	On	On		
4	Reset of output	Off in hardware	Off in hardware		
5	Stop on error cl.	No effect	No effect		
6	Warmstart on E2	Off	Off		

8

---

---

---

---

---

---

VŠB TECHNICKÁ FAKULTA KATEDRA  
UNIVERZITA STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA

### Behavior of central units (CPU) during reset

Reset:

---



---



---



---



---



---

9

VŠB TECHNICKÁ FAKULTA KATEDRA  
UNIVERZITA STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA

### Setting the mode via the display and buttons

Mode 00:  
Mode 01:  
Mode 02:

---



---



---



---



---




---

10

VŠB TECHNICKÁ FAKULTA KATEDRA  
UNIVERZITA STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA

### Control configuration: I/O-Bus



Index	Name	Wert	Defa.	Min	Max
1	Run on config fault	No	No	1	1200
2	Max wait time	0000	0000	200	65535
3	Max failure incidime	2000	5000	200	65535
4	Max failure in succession	10	10	0	255
5	Port number	0	0	0	65535
6	Reserve 1	0	0	0	65535
7	Reserve 2	0	0	0	65535

11

---



---



---



---



---



---

VŠB TECHNICKÁ FAKULTA KATEDRA  
UNIVERSITÁT STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA TECHNIKY A ŘÍZENÍ

**Configuration 16 inputs →**

**Example: inputs from the DC532 module on the I/O-Bus**

**ABB DCS32**

16 DI 16 DO  
Input 24 V DC  
Output 24 V DC 50 mA

**I/O-Bus[0]**

- DC532 - 16 digital input and 16 digital output[0]
- Digital Inputs - 0-15[0]
  - AT %W0.0 WORD, ("input 0-15") [CHANNEL\_0]
  - AT %W0.1 WORD, ("input 1-15") [CHANNEL\_1]
  - AT %W0.2 WORD, ("input 2-15") [CHANNEL\_2]
  - AT %W0.3 WORD, ("input 3-15") [CHANNEL\_3]
  - AT %W0.4 WORD, ("input 4-15") [CHANNEL\_4]
  - AT %W0.5 WORD, ("input 5-15") [CHANNEL\_5]
  - AT %W0.6 WORD, ("input 6-15") [CHANNEL\_6]
  - AT %W0.7 WORD, ("input 7-15") [CHANNEL\_7]
  - AT %W0.8 WORD, ("input 8-15") [CHANNEL\_8]
  - AT %W0.9 WORD, ("input 9-15") [CHANNEL\_9]
  - AT %W0.10 WORD, ("input 10-15") [CHANNEL\_10]
  - AT %W0.11 WORD, ("input 11-15") [CHANNEL\_11]
  - AT %W0.12 WORD, ("input 12-15") [CHANNEL\_12]
  - AT %W0.13 WORD, ("input 13-15") [CHANNEL\_13]
  - AT %W0.14 WORD, ("input 14-15") [CHANNEL\_14]
  - AT %W0.15 WORD, ("input 15-15") [CHANNEL\_15]
- Digital Inputs - 0-15[0]
- Digital Outputs - outputs 16-31[0]
- Ext. counter[0]

12

VŠB TECHNICKÁ FAKULTA KATEDRA  
UNIVERSITÁT STROJNÍ AUTOMATIZAČNÍ  
OSTRAVA TECHNIKY A ŘÍZENÍ

**Configuration 16 inputs →**

**Example: inputs from the DC532 module on the I/O-Bus**


**ABB DCS32**

16 DI 16 DO  
Input 24 V DC  
Output 24 V DC 50 mA

**I/O-Bus[0]**

- DC532 - 16 digital input and 16 digital output[0]
- Digital Inputs - 0-15[0]
  - AT %W0.0 WORD, ("input 0-15") [CHANNEL\_0]
  - AT %W0.1 WORD, ("input 1-15") [CHANNEL\_1]
  - AT %W0.2 WORD, ("input 2-15") [CHANNEL\_2]
  - AT %W0.3 WORD, ("input 3-15") [CHANNEL\_3]
  - AT %W0.4 WORD, ("input 4-15") [CHANNEL\_4]
  - AT %W0.5 WORD, ("input 5-15") [CHANNEL\_5]
  - AT %W0.6 WORD, ("input 6-15") [CHANNEL\_6]
  - AT %W0.7 WORD, ("input 7-15") [CHANNEL\_7]
  - AT %W0.8 WORD, ("input 8-15") [CHANNEL\_8]
  - AT %W0.9 WORD, ("input 9-15") [CHANNEL\_9]
  - AT %W0.10 WORD, ("input 10-15") [CHANNEL\_10]
  - AT %W0.11 WORD, ("input 11-15") [CHANNEL\_11]
  - AT %W0.12 WORD, ("input 12-15") [CHANNEL\_12]
  - AT %W0.13 WORD, ("input 13-15") [CHANNEL\_13]
  - AT %W0.14 WORD, ("input 14-15") [CHANNEL\_14]
  - AT %W0.15 WORD, ("input 15-15") [CHANNEL\_15]
- Digital Inputs - 0-15[0]
- Digital Outputs - outputs 16-31[0]
- Ext. counter[0]

13



The screenshot shows the WinCC Graphics Designer interface. On the left, there is a tree view of project resources under 'Resources' and a list of tasks under 'Task configuration'. A red arrow points from the 'Task configuration' item in the tree view to the 'Task configuration' dialog box on the right. The dialog box has tabs for 'Task configuration' (selected) and 'Task execution'. Inside the 'Task configuration' tab, there is a section titled 'System events' with a checkbox labeled '1'. Below this section, the text 'The right "mouse": Add Task' is displayed.

**Configuration of tasks and cycle times**

**First option**


E      I      A      E      A      E      A      PLC\_PRG

**Second option**

E      A      I      E      A      E      A      Task 1


E      A      E      A      E      A      Task 2

E      A      E      A      Task 3




18

## Interconnection of control systems



19

## Hierarchical management structure



20

## Building blocks of complex control systems (designer's view)

- Actuators and sensors,
- control units at the lowest management level,
- individual subsystems of the hierarchical management structure,
- communication links (vertical, horizontal).

21

---


---

---

---

---

## An example of linking a real task



22

---


---

---

---

---

## Communication links - ISO/OSI reference model



23

---

---

---

---

---

### Communication links

- Individual layers can be implemented
- Most ILAN networks are designed for

24

---

---

---

---

---

---

### RS 485 industrial bus

- Difference between RS232 and RS485
- ...

25

---

---


---

---

---

---

### Work assignment



26

---

---

---

---

---

---

**What did you learn?**

PLC input/output addressing  
I/O configuration and assignment  
Time division of the task – Task  
Priorities  
Communication interface  
ILAN  
... .

27

---

---

---

---

---

---

---

**Thank you for your attention**

28

---

---

---

---

---

---

---